


Low Voltage Concentric Cable

Concentric cable for service entrance and utility distribution review

Low Voltage Concentric Cable is prepared for preliminary product selection and quotation review. This product is used for low or medium voltage service connections and utility distribution where concentric neutral or earth construction is required. Cable structure, conductor material, insulation level and applicable standard should be reviewed according to the project route.



VOLTAGE

0.6/1kV

CONDUCTOR

Copper or aluminum conductor route, according to product standard

TYPICAL USE

Service entrance connections

STANDARDS

KS 04-1022; IEC 60502-1;
SANS 1507; BS 7870-3.21

DATA SCOPE

2 technical table(s) included for preliminary selection

SELECTION NOTE

Confirm voltage, conductor, neutral/earth arrangement, sheath and installation route.

For quotation review, provide cable type, standard, size, quantity and project destination.

ethan@farwalkcable.com | +86 155 5800 6344

Application & Selection Summary

Typical applications

- Service entrance connections
- utility distribution networks
- overhead or underground service routes
- projects requiring concentric neutral or earth cable construction.

Selection logic

- Confirm voltage grade, conductor material, concentric neutral or earth arrangement, installation route and required standard.
- For utility projects, local grid practice and tender documents should be checked before final selection.

Construction Overview

Item	Website-ready content
Product route	Phase conductor with insulation and concentric neutral/earth wires or screen arrangement. Outer sheath and detailed structure depend on the project standard and product type.
Voltage	0.6/1kV
Conductor	Copper or aluminum conductor route, according to product standard
Standards	KS 04-1022; IEC 60502-1; SANS 1507; BS 7870-3.21
Confirmation	Final structure, dimensions and packing should follow selected standard, quotation review and order specification.

Readable Data Index

Data route	Size / rating range	Construction	Diameter / OD	Resistance / weight / rating
Aluminum Straight Concentric (e.g., KS 04-1022 Standard)	1 x 10 - 1 x 35	1.7mm x 5 - 1.7mm x 16	11.5 - 16.8	165 - 650
Copper Split Concentric (BS 7870-3.21)	1 x 10 - 1 x 35	1.35mm x 4 - 1.7mm x 10	12.5 - 18.2	See table

Data boundary: these tables support website launch, quotation review and preliminary product selection. For project execution, final dimensions, electrical performance, packing and compliance documents should be confirmed against the selected project standard and order specification.

Aluminum Straight Concentric (e.g., KS 04-1022 Standard)

Reference table for preliminary selection and quotation review.

Nom. Area (mm²)	Phase Conductor Dia. (mm)	Concentric Layer Wires	Approx OD (mm)	Weight (kg/km)
Aluminum Straight Concentric (e.g., KS 04-1022 Standard)				
1 x 10	4.0	1.7mm x 5	11.5	165
1 x 16	5.1	1.7mm x 7	13.2	210
1 x 25	6.4	2.1mm x 7	15.5	310
1 x 35	7.5	2.1mm x 10	17.2	420
Copper Straight Concentric (e.g., BS 7870 Standard)				
1 x 10	4.0	1.35mm x 7	11.2	225
1 x 16	5.1	1.35mm x 11	12.8	315
1 x 25	6.4	1.7mm x 11	15.2	485
1 x 35	7.5	1.7mm x 16	16.8	650

Copper Split Concentric (BS 7870-3.21)

Reference table for preliminary selection and quotation review.

Nom. Area (mm ²)	Phase Conductor Dia. (mm)	Insulated Neutral Wires	Bare Earth Wires	Approx OD (mm)
Copper Split Concentric (BS 7870-3.21)				
1 x 10	4.0	1.35mm x 4	1.35mm x 3	12.5
1 x 16	5.1	1.35mm x 7	1.35mm x 4	14.2
1 x 25	6.4	1.7mm x 7	1.7mm x 4	16.5
1 x 35	7.5	1.7mm x 10	1.7mm x 6	18.2